



## WOOD FENCE INSTALLATIONS REQUIREMENTS

- Wood fences shall be constructed of decay and termite resistant material, as specified in Section 2326 of the 2010 Florida Building Code (FBC)
- Wood fences shall be designed according to the loads as specified in Section 2328 (FBC).

**EXCEPTION:** Unless designed by rational analysis, wood fences not exceeding 6' in height may be constructed to meet the following minimum requirements:

- Vertical post of P.T. 4 x 4" spaced according to detail "A" below.
- Post shall be embedded 2' into a concrete footing 10" in diameter.
- Horizontal framing shall consist of a minimum of 3 horizontal rails of 2 x 4" material and shall be fastened with 2-16D nails at each post, according to Chapter 2334.1.
- All lumber shall be a minimum of #2 grade or better.
- All fasteners shall be corrosion resistant.

**ZONING REQUIREMENT:** Decorative side (good side) must face out, City Code Sec. 13-379

**POOL REQUIREMENTS:** Fence must be a minimum of 5' high with self-closing, self-latching gates that swing out and away from the pool.

**WARNING:** Pre-manufactured sections may not comply with this code. Product approval may be required.

